

ROY COOPER
 Governor
 ELIZABETH S. BISER
 Secretary
 RICHARD E. ROGERS, JR.
 Director



Certified Mail # 7021 0950 0001 8685 3597
Return Receipt Requested

May 8, 2023

Prem Gupta
 Gwwtp LLC
 PO Box 90
 Kill Devil HI, NC 27948

SUBJECT: NOTICE OF VIOLATION
 Tracking Number: NOV-2023-LV-0315
 Permit No. WQ0017224
 Ginguite Woods WWTP
 Dare County

Dear Mr. Buck:

A review of the January 2023 Non-Discharge Monitoring Report (NDMR) for the subject facility revealed the violation(s) indicated below:

Limit Exceedance Violation(s):

Sample Location	Parameter	Date	Limit Value	Reported Value	Type of Violation
001	Coliform, Fecal MF, MFC Broth, 44.5 C (31616)	1/24/2023	25	35	Daily Maximum Exceeded
001	Turbidity, HCH Turbidimeter (00076)	1/25/2023	10	22.1	Daily Maximum Exceeded
001	Coliform, Fecal MF, MFC Broth, 44.5 C (31616)	1/31/2023	14	35	Monthly Geometric Mean Exceeded

Reporting Violation(s):

Sample Location	Parameter	Date	Type of Violation
001	Nitrogen, Kjeldahl, Total (as N) (00625)	1/31/2023	Parameter Missing



Remedial actions, if not already implemented, should be taken to correct any noted problems. The Division of Water Resources may pursue enforcement actions for this and any additional violations. If the violations are of a continuing nature, not related to operation and/or maintenance problems, and you anticipate remedial construction activities, then you may wish to consider applying for a Special Order by Consent (SOC).

If you have any questions concerning this matter or to apply for an SOC, please contact Victoria Herdt of the Washington Regional Office at 252-948-3844.

Sincerely,

Robert Tankard

Robert Tankard, Assistant Regional Supervisor
Water Quality Regional Operations Section
Washington Regional Office
Division of Water Resources, NCDEQ

Cc: Laserfiche

